



# Certificate of Compliance

**Certificate:** 2316175 (LR63938)

**Master Contract:** 157869

**Project:** 2316175

**Date Issued:** June 22, 2010

**Issued to:** American Power Conversion Corp.

85 Rangeway Rd Bldg 2  
North Billerica, MA 01862  
USA  
Attention: John Coviello

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Andrew Kruminis P. Eng.*

**Issued by:** Andrew Kruminis P. Eng.

## **PRODUCTS**

**CLASS 5311 88** - POWER SUPPLIES - Uninterruptible Power Systems - Certified to US Standards

**CLASS 5311 08** - POWER SUPPLIES - Uninterruptible Power Systems

Cord Connected Uninterruptible Power Systems

### **PART A:**

Models. SMX1500RM2U, SMX1500RM2UNC

Rated: 120 V ac, 50/60 Hz, 12A input; 120 V ac, 1440VA, 50/60 Hz, 1200W, 12A Total current, output

### **PART B**

Model SMX1000

Rated: 120 V ac, 50/60 Hz, 12A input; 120 V ac, 1000VA, 50/60 Hz, 800W, 8.33A Total current, output

### **PART C**

SMX750



**Certificate:** 2316175 (LR63938)

**Master Contract:** 157869

**Project:** 2316175

**Date Issued:** June 22, 2010

---

Rated: 120 V ac, 50/60 Hz, 12A input; 120 V ac, 750VA, 50/60 Hz, 600W, 6.25A Total current, output

Note: The above catalog numbers may be provided with the suffix 'XXXXX' where X denotes any number, dash or letter to denote non-safety critical marketing differences

**APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No 107.3-05 Uninterruptible Power Systems

UL 1778 4th Ed. Uninterruptible Power Systems